

कार्यालय सहायक अभियंता, लोक स्वास्थ्य यंत्रिकी उपखण्ड घरघोड़ा,
जिला-रायगढ़ (छ.ग.)

पत्र क्र. 154 / स.अ. / लो.स्वा.यॉ. / 2020

घरघोड़ा,दिनांक 16/03/2020

प्रति,


✓
प्राचार्य,
उर्सुलाईन इंगलिश मेडियम स्कूल,
पतरापारा धरमजयगढ़,
जिला-रायगढ़ (छ.ग.)

विषय :- जल नमूना परीक्षण रिपोर्ट के संबंध में।

-00-

उपरोक्त विषयांतर्गत संदर्भित पत्र के साथ आपके द्वारा भेजे गए जल नमूनों का परीक्षण का परीक्षण रिपोर्ट संलग्न कर आपकी ओर प्रेषित है।

सहपत्र:- 01. जल नमूना परीक्षण रिपोर्ट।
02. प्रोफार्मा बिल।


सहायक अभियंता
लो.स्वा.यॉ. उपखण्ड घरघोड़ा
जिला - रायगढ़ (छ.ग.)


पृ. क्र. 155 / स.अ. / लो.स्वा.यॉ. / 2020

घरघोड़ा / दिनांक - 16/03/2020

प्रतिलिपि:-

कार्यपालन अभियंता लोक स्वास्थ्य यंत्रिकीय खण्ड रायगढ़ (छ.ग.) की ओर सादर सूचनार्थ
सम्प्रेषित।

सहपत्र:- 01. जल नमूना परीक्षण रिपोर्ट।
02. प्रोफार्मा बिल।


सहायक अभियंता
लो.स्वा.यॉ. उपखण्ड घरघोड़ा
जिला - रायगढ़ (छ.ग.)

SUB. DIVISIONAL WATER TESTING LABORATORY - GHARGHODA
(NATIONAL DRINKING WATER MISSION)

DISTRICT Raigarh
(Code No.)

BLOCK Dharamjigarh
(Code No.)

VILLAGE U.E.M. School Patrapada
Dharamjigarh

Particulars of sample

- (i) Date of Collection 12.03.2020
(ii) Date of Received 12.03.2020
(iii) Date of Analysis 12.03.2020

Details of Location & Source

- (i) Base Well Row water
(ii) Base Well filter water
(iii)
(iv)
(v)

Reference (if any)

Sample Collected by

Sl. No.	Characteristics	Units	Acceptable	Cause for rejection	RESULTS					
					I	II	III	IV	V	
PHYSICAL										
1.	Temperature	°C	-	-	28°	28°				
2.	Turbidity	N.T.U.	1.0	5.0	1.75	1.25				
3.	Colour	Pt. Cobalt Scale	5.0	15	NIL	NIL				
4.	Taste & Odour	-	Unobjectionable	Unobjectionable		unobj				
CHEMICAL										
5.	PH	PH Scale	7.0 To 8.5	6.5 To 9.2	7.25	7.10				
6.	Conductivity	Micro mhos/cm	-	-		Not tested				
7.	Total Alkalinity	mg/l	-	-		Not tested				
8.	Chlorides	mg/l	200	1000	300	260				
9.	Nitrates	mg/l	45	45	-	-				
10.	Total Hardness as Ca CO ₃	mg/l	200	600	70	62				
11.	Calcium (as Ca)	mg/l	75	200	44	38				
12.	Magnesium (as mg)	mg/l	30	100	26	24				
13.	Total Dissolved Solids	mg/l	200	500	-	-				
14.	Iron	mg/l	0.10	1.0	NIL	NIL				
15.	Fluorides	mg/l	0.10	1.5	NIL	NIL				
16.	Residual Chlorine by Jar Test	ppm	0.2	1.0						
17.	Coagulant Dose Bacteriological	mg/l	-	-						
18.	Coliform Organisms at 37 °C	M.P.N 100 ml	24 Hr. 48 Hr.		NIL	NIL				
19.	Fecal Coliforms	Per 100 ml			NIL	NIL				
20.	Special Test :-									
	(i)									
	(ii)									
REMARKS		<p style="color: red; text-align: center;">Water Sample Collected by Client जल नमूना अधिकृत रूप से नहीं लिया गया है; अतः रिपोर्ट न्यायालयीन कार्य के लिए अनुपयुक्त है।</p>								

TESTED BY

[Signature]

LAB. ASSISTANT

Water Testing Lab.-Gharghoda
Dist. - RAIGARH (C.G.)

[Signature]

CHEMIST INCHARGE

Water Testing Lab.
P.H.E. Department-Gharghoda
Dist. - Raigarh (C.G.)

[Signature]

ASSISTANT ENGINEER

P.H.E. Sub-division-Gharghoda
Dist. - Raigarh (C.G.)

P.H.E. SUB DIVISION GHARGHODA
DISTRICT-RAIGARH (C.G.)
SUB DIVISIONAL WATER TESTING LAB

NO. -----/AE/PHE/2020

Gharghoda/Dated -----

PROFORMA BILL

To,

✓ Principal,
Ursuline English Medium School,
Patrapara Dharamjaigarh,
Distt.-Raigarh (C.G.)


Kindly arrange to deposited the cost of following materials demanded through your indent No./Letter No. Dated 12.03.2020 As details given bellow, the amount may be Deposited in favor The Executive Engineer.Public Helth Engineer,Division-Raigarh (C.G.)

Sl.No.	Name Of Tests	Quantity	Rate	Unit	Amount
1	Physical & Chemical test	02	350.00	Per	700.00
2	Bacteriological test	02	200.00	Per	400.00
Total Rs:-					1100.00


(Rs. One Thousand One Hundred Only)


Signature of Receiver


PRP
Ursuline English Medium School
Patrapara Dharamjaigarh
Distt.-Raigarh (C.G.) Pin-496116



Lab - In/Charge
P.H.E. Sub-Division
Gharghoda


MANAGER
Ursuline English Medium School
Patrapara Dharamjaigarh
Distt.-Raigarh (C.G.) Pin-496116


ASSISTANT ENGINEER
P.H.E. Sub- Division
Gharghoda

Copy Forwarded to :-

Executive Engineer,Public Helth Engineer,Division_Raigarh (C.G.) for necessary action.


ASSISTANT ENGINEER
P.H.E. Sub- Division
Gharghoda